

Certificate

This is to certify that **Firestryker Australasia Pty Ltd**

ABN 50 629 459 187

Head Office Address Suite 7, Level 1
186 Hampton Road
Nedlands
Western Australia
6909, Australia

Holds Certificate Number **BMP 745429**

Is authorised to use the BSI registered Benchmark Product Certification Trademark, on products identified in the Product Certification Schedule that is attached to this Product Certification Certificate. Such products have been Type Tested and are manufactured under the Product Certification Requirements monitored by BSI to ensure that the manufacturing process has the capability to consistently produce products in compliance with and are Certified to:

AS 4265:1995 Wheeled fire extinguishers

For and on behalf of BSI

Marc Barnes, Managing Director, BSI Group ANZ Pty Ltd

Originally registered
02/07/2021

Latest issue
14/02/2023

Expiry date
01/07/2026



...making excellence a habit.

Schedule

This schedule supports the Product Certification Certificate for Firestryker Australasia Pty Ltd

ABN 50 629 459 187

Head Office Address Suite 7, Level 1
186 Hampton Road
Nedlands
Western Australia
6909, Australia

Holds Certificate Number BMP 745429

Standard AS 4265:1995 Wheeled fire extinguishers

Issue date 14/02/2023

Model	BSI Review Date	Description
FS45LF-500T	14/02/2023	45L Water type with F-500 Encapsulating agent wheeled fire extinguisher stored pressure. 3A:10B:4F Capable of extinguishing Lithium-Ion battery fires.
FS90LF-500T	14/02/2023	90L Water type with F-500 Encapsulating agent wheeled fire extinguisher stored pressure. 3A:10B:4F Capable of extinguishing Lithium-Ion battery fires.

BMP 745429
14/02/2023 Page 2 of 2



...making excellence a habit.