



Certificate

This is to certify that

Firestryker Australasia Pty Ltd

ABN

50 629 459 187

Head Office Address

Suite 7, Level 1
186 Hampton Road
Nedlands
Western Australia
6909, Australia

Holds Certificate Number

BMP 745422

Is authorised to use the BSI registered Benchmark Product Certification Trademark, on products identified in the Product Certification Schedule that is attached to this Product Certification Certificate. Such products have been Type Tested and are manufactured under the Product Certification Requirements monitored by BSI to ensure that the manufacturing process has the capability to consistently produce products in compliance with and are Certified to:

AS/NZS 1841.2:2007 Portable fire extinguishers - Specific requirements for water type extinguishers

For and on behalf of BSI

Marc Barnes, Managing Director, BSI Group ANZ Pty Ltd

Originally registered
01/07/2021

Latest issue
01/07/2021

Expiry date
30/06/2026



...making excellence a habit.

The use of this certificate and of the Benchmark Product Certification mark trademark is subject to the Client complying with the BSI Mark Requirements, and Terms and Conditions. BSI Group ANZ Pty Ltd, Suite 1, Level 1, 54 Waterloo Road, Macquarie Park, NSW 2113
The validity of this certificate can be checked at website: www.bsi-global.com/clientdirectory and the JASANZ website: www.jas-anz.org/register. This certificate remains the property of BSI and must be returned upon its request. Template updated September 2020.

Schedule

This schedule supports the Product Certification Certificate for Firestryker Australasia Pty Ltd

ABN 50 629 459 187

Head Office Address Suite 7, Level 1
186 Hampton Road
Nedlands
Western Australia
6909, Australia

Holds Certificate Number BMP 745422

Standard AS/NZS 1841.2:2007 Portable fire extinguishers - Specific requirements for water type extinguishers

Issue date 15 December 2021

Model	BSI Review Date	Description
FS9LF-500	24/09/2021	9.0 Litre water type with F-500 encapsulating agent. Ratings 3A:10B:C:3F:D (lithium ion only)
FS4LF-500	24/09/2021	4.0 Litre water type fire extinguisher with F-500 encapsulating agent Ratings 2A:2B:C:3F:D (lithium ion only)